



Product Service

# EC-Attestation of Conformity

No. E8 06 07 54505 027

**Holder of Certificate:** KUN HUNG ELECTRIC CO., LTD.  
 113-4, Jangan-Dong, Dongdaemoon-Gu  
 130-100 SEOUL  
 KOREA

**Name of Object:** Industrial, Scientific and Medical equipment  
 Photo Sensor

**Model(s):** KPS-ALTR, KPS-ALTRP

**Description of Object:**  
 Rated input voltage: 24-240 Va.c./Vd.c.  
 Rated input power: 2 Wmax.

**Tested according to:** EN 55011:1998+A1:1999+A2:2002  
 EN 60947-5-2:1998+A1:1999+A2:2004

This EC-Attestation of Conformity is issued according to the Directive 89/336/EEC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed equipment complies with the principal protection requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

**Test report no.:** SKTCEE-060619-069



**Date,** 2006-07-11

**CE** After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.