



Product Service

# EC-Attestation of Conformity

No. N8 07 07 54505 032

**Holder of Certificate: KUN HUNG ELECTRIC CO., LTD.**113-4, Jangan-Dong, Dongdaemoon-Gu  
SEOUL 130-100  
REPUBLIC OF KOREA**Product: Low voltage switchgear combination  
(Select Switch)**

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** CPSA0122567

Date, 2007-07-11



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



**EC-Attestation of Conformity**  
**No. N8 07 07 54505 032**

**Model(s):** KSL 25 a b - c d, KSL 30 a b - c d

**a. IP Code**  
 Blank: IP40  
 W: IP65

**b. Operation part type**  
 S2: 2-step manual short lever  
 L2: 2-step manual long lever  
 S3: 3-step manual short lever  
 L3: 3-step manual long lever  
 AS2: 2-step automatic short lever  
 AL2: 2-step automatic long lever  
 AS3: 3-step automatic short lever  
 AL3: 3-step automatic long lever

**c. Number of NO contacts**  
 1 to 4: SPDT - NO

**d. Number of NC contacts**  
 1 to 4: DPDT - NC

**Parameters:**

Rated input voltage:	125/250 V a.c.
Rated input current:	10 A/ 6 A
Rated insulation voltage:	250 V a.c./d.c
Rated impulse withstand voltage:	4 kV
Utilization category:	AC-12 (Resistive)
Degree of protection:	IP40 or IP65
Pollution degree:	3
Overvoltage category:	III
Number of operating cycles:	100000 (electrical) 1000000 (mechanical)
Rated Conditional Short-Circuit Current:	1 KA
Remark:	When installing/inserting the equipment all requirements of the mentioned test standards must be fulfilled.

**Tested according to:** EN 60947-1:2004  
 EN 60947-5-1:2004